

100012345BOM_00.doc

‘....frontpage....’

QTY	ITEM	DESCRIPTION - FUNCTION	MANUFACTURER	MODEL	RANGE	REMARKS
1	A1	Kompaktschaltschrank lackiert, mit Montageplatte	Rittal	AE1180500-F		
4	F1-F7	SLP 100 3-phase Fuse 3x63A	ABB	SLP100	63A	
4	F2-F8	SLP 100 3-phase Fuse 3x63A	ABB	SLP100	63-125A	
12	H2-H13	Lamp socket Alarm (RED)	EAO	61-0010.02	Ø18 mm	
12	H2-H13			761.9311.2		
12	H2-H13	Lamp Diode	eao	10.2312.1065	24V DC, Green	
12	H2-H13	Lamp Lens	eao	51.953.5	Green 18x18	
12	H2-H13	Lamp Socket	eao	51.050.005	18x18	
2	KM1-KM5	AUXILIARY SWITCH BLOCK, 02, 2NC, DIN	Siemens AG	3RH19111FA02		
1	KM1			AddPart1		
5	KM1-KM5	CONTACTOR, AC-3 3 KW/400 V, 1 NO, AC 24	Siemens AG	3RT10151AB01		
4	M1-M5	Drehstrommotor mit Käfigläufer, 4 kW, 2900	VEM	K21R-112-M2		
2	M1-M5			AddPart1		
2	M1-M5			AddPart2		
1	M3	Drehstrommotor mit Käfigläufer, 4 kW, 2900	VEM	K21R-112-M2		Remark
1	M3	Drehstrommotor mit Käfigläufer, 4 kW, 2900	VEM	K21R-112-M2		
2	QM1-QM2	CIRCUIT-BREAKER, SIZE S00, FOR MOTOR	Siemens AG	3RV10110DA15		
2	W5-W7	Datenleitung mit Kupferabschirmgeflecht	Lapp	LIYCY-3X0.14	50 m	
2	W5-W7			AddPart1		
2	W6-W8	Datenleitung mit Kupferabschirmgeflecht	Lapp	LIYCY-3X0.14	50 m	
2	W6-W8			AddPart1		
52	X100	3-CONDUCTOR THROUGH TERMINAL	WAGO GmbH	279-681		
1	X100	3-CONDUCTOR THROUGH TERMINAL	WAGO GmbH	279-681	12VDC	
1	X100	3-CONDUCTOR THROUGH TERMINAL	WAGO GmbH	279-681	240VDC	
4	XT1	4-CONDUCTOR MINIATURE THROUGH	WAGO GmbH	264-721		
2	XT2	4-CONDUCTOR MINIATURE THROUGH	WAGO GmbH	264-724		

						CUSTOMER LOGO	System Test Bill of material	FKS DOC NO.
								LIST-CUSDRAWNO
00	For review	26.11.03	ANY	LKV	APPR			
Rev.	Reason for rev.	Date	Prep. by	Chk. By	Appr. by	DEA DOC NO.: 100012345BOM_00.doc		SHEET 2 of 2